



**Builder's Best, Inc.**  
 201 Broiles Drive  
 Jacksonville, TX 75766  
 903-586-8283  
 www.BuildersBest.com  
 sales@venting.biz

# VINYL BATH VENT KITS



## PART NUMBERS

Hose	Hood	Clamps	Part #	Qty	Package
4" x 8' Vinyl	Wide Mouth Aluminum	2 Zip Torq	111522	8	Display Box
4" x 8' Vinyl	Brown Louvered Plastic	2 Zip Torq	111510	6	Display Box
4" x 8' Vinyl	White Louvered Plastic	2 Zip Torq	111511	6	Display Box
4" x 8' Vinyl	White Wide Mouth Plastic with Bird Guard	2 Zip Torq	111517	8	Display Box



## PRODUCT SPECIFICATIONS

These kits are suitable for installations which do not require a UL® label.

### 4" x 8' Standard Vinyl Hose:

- Steel wire support
- 1½" Pitch

One of the following hoods:

#### AWM271 Aluminum Wide Mouth Vent Hood

- 11.5" fully assembled, riveted tailpipe
- Back draft flapper

#### PML282 Louvered Plastic Hood in White or Brown

- Low profile with freeswinging louvers
- 11" fully assembled, riveted tailpipe

#### PMW113 Wide mouth plastic hood with bird guard

- 11" fully assembled, riveted tailpipe
- ½" x ½" pest grid snaps in and removable for cleaning



### Two 4" Zip Torque™ Plastic clamps

- Unique polymeric stretch plastic
- Tightens without tools and loosens with #2 phillips screwdriver  
 US Patent 9,377,141 B2

## DISPLAY SAMPLE



## PERFORMANCE DATA - VINYL

- Recommended Operating Pressure:  
 Max positive: 1" w.g. -all diameters  
 Max negative: ½" w.g. - all diameters
- Maximum velocity: 2,000 FPM
- Operating Temp. Range:  
 -20°F to 100°F continuous  
 -20°F to 120°F intermittent

## LABELS

### WARNING

This Product Can Expose You To Chemicals Including **ANTIMONY TRIOXIDE** And **2-ETHYLHEXYL** Which Are Known To The State Of California To Cause Cancer For More Information go to <https://www.p65warnings.ca.gov>

## RECOMMENDATIONS

The International Mechanical Code recommends rigid metal duct for dryer exhaust as well as in wall exhaust. IMC 504.6.1 & 504.8-3

Dryer manufacturers specify "Only rigid or flexible metal vent shall be used for exhausting. Do not use plastic or metal foil vent."

This kit is not recommended for dryer venting. It is suitable for bath fan venting.

## WARRANTY

Complete warranty statement at <https://www.buildersbest.com>

